



CERTIFICATE OF TEST

Date of issue: 16 September 2008

Project number: 08/0647

Applicant: Cooper MEDC Limited

Reference: 0676

Address: Pinxton
Nottingham
NJ16 6JF

Test record sheet: TR/08/0647/01

Description of Test Sample

A Type CU1 Combination Beacon/Sounder unit to Baseefa 04ATEX0273X.

Drawings

None.

Specification

Ingress protection test IPX6 to IEC60529.

Result

Pass.

Comments

None.

Test carried out by: M Needham

Checked and approved by: C R Spicer

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.



Baseefa

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com
Baseefa is a trading name of Baseefa Ltd
Registered in England No. 4305578. Registered address as above.

R S SINCLAIR
DIRECTOR
On behalf of
Baseefa