



# 中国国家强制性产品认证证书

证书编号：2015010304830298

委托人名称、地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

生产者（制造商）名称、地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB 新会低压开关有限公司  
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

软起动器

PSTX1050-600-70, PSTX1250-600-70, PSTX1050-690-70, PSTX1250-690-70; 详细参数  
型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2018年03月08日 有效期至：2020年12月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2015年12月17日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.: 2015010304830298**

## **NAME AND ADDRESS OF THE APPLICANT**

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## **NAME AND ADDRESS OF THE MANUFACTURER**

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## **NAME AND ADDRESS OF THE FACTORY**

ABB Xinhui Low Voltage Switchgear Co., Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,  
P.R.China

## **PRODUCT NAME, MODEL AND SPECIFICATION**

Soft Starters  
PSTX1050-600-70, PSTX1250-600-70, PSTX1050-690-70, PSTX1250-690-70; See the app  
endix

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** Mar.08,2018

**Valid until:** Dec.17,2020

The validity of the certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

Date of original issued: Dec.17,2015

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



## **CHINA QUALITY CERTIFICATION CENTRE**





# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2015010304830298

纸 号: 1917087

PSTX1050-600-70, PSTX1250-600-70,  
 PSTX1050-690-70, PSTX1250-690-70;  
 PSTX1050-600-70, PSTX1250-600-70,  
 $U_i: 600V; U_e: 208-550V AC$  ;  
 $I_{th} = I_e: 1050A (PSTX1050-600-70)$  ;  
 $1250A (PSTX1250-600-70)$   
 PSTX1050-690-70, PSTX1250-690-70  
 $U_i: 690V; U_e: 208-690V AC$  ;  
 $I_{th} = I_e: 1050A (PSTX1050-690-70)$  ;  
 $1250A (PSTX1250-690-70)$

Pe:

产品型号	额定工作 电 流 $I_e$ (A)	额定功率(kW)			
		220-230V	380-400V	500V	690V
PSTX1050-600-70	1050	315	560	730	-
PSTX1250-600-70	1250	400	710	880	-
PSTX1050-690-70	1050	315	560	730	1000
PSTX1250-690-70	1250	400	710	880	1200

AC-53a; 3P

注: 此附录与证书同时使用时有效。



主 任:



## 中国质量认证中心





# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2015010304830298

纸 号：1917087

型号解释：

PSTX	***	-	***	-	70
1	2		3		4

- 1 = Softstarter, name of series
- 2 = Current rating, Inline Ie,: 1050=1050A, 1250=1250A
- 3 = Operational voltage, Ue: 600 = 208-550V AC, 690 = 208-690V AC
- 4 = Control supply voltage, Us: 70 = 100 - 250V AC

注：此附录与证书同时使用时有效。



主 任：



## 中国质量认证中心